

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 214

Date : 07/02/26

It is certified that an inspection team headed by For. Ramesh Kumar
Executive Engineer (Name of Officers
with designation) from PHEO (P.H. Division, Darbhanga) (Name of
Department/Office) inspected the S.S. International public
School, Vill+P.O.-Kargapatti, P.S.-Kamtaul, Darbhanga (Name & Address of
the School) on 07/02/2026 and found that the S.S. International
public School. (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of one year.

Signature with Seal : [Signature]
Name : For. Ramesh Kumar
Designation : _____

To

Principal
S.S. International public
School, Vill+P.O.-Kargapatti, Darbhanga,
(Name & Address of the Institution) Pin-844306

A.K. Choudhary
PRINCIPAL
S.S. INTERNATIONAL PUBLIC SCHOOL
PIN-844306

[Signature]
MANAGER
S.S. INTERNATIONAL
PUBLIC SCHOOL

District Level Water Quality Testing Laboratory
Public Health Engineering Department
P.H. Division, Darrhanga
TEST CERTIFICATE

Location:- S.S. International Public School, Village-
Karjapatti, Panchayat-Karjapatti, Block- Keoti

Sample Collected by:- Chemist

Source of Sample:- H/P

Date of Testing:- 07.02.2026

Date of Sampling:- 07.02.2026

Date of Receiving in Lab:- 07.02.2026

PHYSICO - CHEMICAL TEST REPORT

Sl. No.	Parameters	Desirable Limit	Permissible Limit in absence of alternate source	Method of testing Parameters	Test Result	Remarks
01	02	03	04	05		
01	pH Value	6.5-8.5	No Relaxation	pH meter	06	07
02	Turbidity, NTU, Max	05	10	Nephelometer	8.74 ✓	
03	Conductivity U mho/cm			Conductivity meter	02 -	
04	Total Dissolved solid, mg/l, Max	500	2000	Conductivity meter	Not Tested -	
05	Total Hardness (as CaCO ₃), mg/l Max	300	600	EDTA method	Not Tested -	
06	Calcium (as Ca), mg/l, Max	75	200	EDTA method	244 -	
07	Magnesium (as Mg), mg/l, Max	30	100	EDTA method	59.2 -	
08	Chloride (as Cl), mg/l, Max	250	1000	EDTA method	21.31 -	
09	Alkalinity (as CaCO ₃), mg/l, Max	200	600	Titration	124 -	
10	Iron (as Fe), mg/l, Max	0.30	0.30	Titration	336 -	
11	Nitrate (as NO ₃), mg/l, Max	45	No Relaxation	Phenanthroline	0.30 -	
12	Sulphate (as SO ₄), mg/l, Max	200	400	UV-method	25 -	
13	Fluoride (as F), mg/l, Max	1.00	1.50	Turbidity method	50 ✓	
14	Arsenic (as As), mg/l, Max	0.01	0.10	SPANDS	0.20 ✓	
15	MPN of Total Coliform in 100 ml.			UV-method	Not Tested	
				Test tube technique	Absent	

**Given Water Sample
is fit for Drinking**

Note:-

- * BDL means Below detection limit.
- Drinking Water specification First Revision-15:10500:1991 Edition 2.2(2003-09) (Reaffirmed 1993).
- All the testing parameters methods are taken by APHA 20th Edition.
- Not test due to chemical deficiency and Apparatus disorder.

A.K. Choudhary
PRINCIPAL
S.S. INTERNATIONAL PUBLIC SCHOOL
Karjapatti (Darrhanga) Pin-847306
Phone No.-65678

MANAGER
S. S. INTERNATIONAL
PUBLIC SCHOOL
KARJAPATTI, DARRHANGA

CHEMIST
P.H. Division, Darrhanga